



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **MAROA**

Address: P.O. BOX 382

City, State, Zip: MAROA, IL 61756

Facility Number: **1150300**

Date Received: 04/01/25

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Matrix: Drinking Water

Units: ug/L

Analyte **Copper**

Regulatory Level (ug/L): 1300

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25D0019-01	LC4T003	308 W Lincoln	611		50.0	4/10/2025	03/26/25 14:05
25D0019-02	LC4T004	415 S Chestnut	777		50.0	4/10/2025	03/27/25 10:15
25D0019-03	LC4T005	414 S Walnut	1160		50.0	4/10/2025	03/28/25 16:15
25D0019-04	LC4T006	307 S Chestnut	714		50.0	4/10/2025	03/27/25 06:00
25D0019-05	LC4T024	320 S Walnut	329		50.0	4/10/2025	03/27/25 06:32
25D0019-06	LC4T007	128 S Elm	215		50.0	4/10/2025	03/26/25 11:00
25D0019-07	LC4T008	416 N Locust	1060		50.0	4/10/2025	03/27/25 06:15
25D0019-08	LC4T009	230 N Olive	1170		50.0	4/10/2025	03/27/25 06:30
25D0019-09	LC4T010	309 S Locust	1250		50.0	4/10/2025	03/28/25 08:00
25D0019-10	LC4T011	328 W Washington	211		50.0	4/10/2025	03/28/25 06:30
25D0019-11	LC4T018	336 S Locust	158		50.0	4/10/2025	03/28/25 17:40
25D0019-12	LC4T019	114 S Oak	136		50.0	4/10/2025	03/27/25 17:26
25D0019-13	LC4T020	222 N Maple	577		50.0	4/10/2025	03/26/25 15:30
25D0019-14	LC4T025	118 Montgomery Ct	220		50.0	4/10/2025	03/27/25 05:37
25D0019-15	LC4T021	222 W Lincoln	740		50.0	4/10/2025	03/31/25 06:00
25D0019-16	LC4T026	103 E Madison	ND		50.0	4/10/2025	03/27/25 06:39
25D0019-17	LC4T022	412 N Oak	705		50.0	4/10/2025	03/27/25 08:30
25D0019-18	LC4T027	121 S Elm	178		50.0	4/10/2025	04/01/25 06:37



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **MAROA**

Address: P.O. BOX 382

City, State, Zip: MAROA, IL 61756

Facility Number: **1150300**

Date Received: 04/01/25

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Matrix: Drinking Water

Units: ug/L

Analyte **Copper**

Regulatory Level (ug/L): 1300

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25D0020-01	LC3T001	223 S Locust	656		50.0	4/10/2025	03/27/25 08:30
25D0020-03	LC3T002	330 S Walnut	261		50.0	4/10/2025	03/28/25 13:00



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **MAROA**

Address: P.O. BOX 382

City, State, Zip: MAROA, IL 61756

Facility Number: **1150300**

Date Received: 04/01/25

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Matrix: Drinking Water

Units: ug/L

Analyte **Lead**

Regulatory Level (ug/L): 15

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25D0019-01	LC4T003	308 W Lincoln	ND		5.00	4/10/2025	03/26/25 14:05
25D0019-02	LC4T004	415 S Chestnut	ND		5.00	4/10/2025	03/27/25 10:15
25D0019-03	LC4T005	414 S Walnut	ND		5.00	4/10/2025	03/28/25 16:15
25D0019-04	LC4T006	307 S Chestnut	ND		5.00	4/10/2025	03/27/25 06:00
25D0019-05	LC4T024	320 S Walnut	ND		5.00	4/10/2025	03/27/25 06:32
25D0019-06	LC4T007	128 S Elm	ND		5.00	4/10/2025	03/26/25 11:00
25D0019-07	LC4T008	416 N Locust	ND		5.00	4/10/2025	03/27/25 06:15
25D0019-08	LC4T009	230 N Olive	ND		5.00	4/10/2025	03/27/25 06:30
25D0019-09	LC4T010	309 S Locust	ND		5.00	4/10/2025	03/28/25 08:00
25D0019-10	LC4T011	328 W Washington	ND		5.00	4/10/2025	03/28/25 06:30
25D0019-11	LC4T018	336 S Locust	10.0		5.00	4/10/2025	03/28/25 17:40
25D0019-12	LC4T019	114 S Oak	ND		5.00	4/10/2025	03/27/25 17:26
25D0019-13	LC4T020	222 N Maple	ND		5.00	4/10/2025	03/26/25 15:30
25D0019-14	LC4T025	118 Montgomery Ct	ND		5.00	4/10/2025	03/27/25 05:37
25D0019-15	LC4T021	222 W Lincoln	ND		5.00	4/10/2025	03/31/25 06:00
25D0019-16	LC4T026	103 E Madison	ND		5.00	4/10/2025	03/27/25 06:39
25D0019-17	LC4T022	412 N Oak	ND		5.00	4/10/2025	03/27/25 08:30
25D0019-18	LC4T027	121 S Elm	ND		5.00	4/10/2025	04/01/25 06:37



Illinois Environmental Protection Agency Laboratory

825 N. Rutledge Springfield, Illinois 62702 217.782.9780

LABORATORY RESULTS

Client: **MAROA**

Address: P.O. BOX 382

City, State, Zip: MAROA, IL 61756

Facility Number: **1150300**

Date Received: 04/01/25

Metals (Drinking Water) by EPA 200 Series Methods ICP/MS

Method: 200.8

Matrix: Drinking Water

Units: ug/L

Analyte **Lead**

Regulatory Level (ug/L): 15

10 ug/L = 0.01 mg/L

<u>Lab ID</u>	<u>Sample Point</u>	<u>Sample Location</u>	<u>Result</u>	<u>Qualifier</u>	<u>Reporting Limit</u>	<u>Analysis Date</u>	<u>Sampled</u>
25D0020-02	LC3T001	223 S Locust	ND		5.00	4/10/2025	03/27/25 08:30
25D0020-04	LC3T002	330 S Walnut	ND		5.00	4/10/2025	03/28/25 13:00